



Confirmation

Eurofins Product Testing A/S confirms that a sample of a Fire protection coating for wooden surfaces with the name

HENSOTHERM 1 KS INNEN

supplied by

Rudolf Hensel GmbH

showed low VOC contents in a test specified in LEED 2009 credit EQ c4.2 (paints and coatings).

VOC contents were below the limit value specified as 350 grams VOC minus water per liters for "Fire-Proofing Coatings".

The test has been performed in March 2012, test report no. G15973B.

Volatiles content was calculated by Eurofins.
Water content was given by the client.
Content of exempt compounds was set to zero.
Solids content was determined by Eurofins.

With this confirmation, use of product HENSOTHERM 1 KS INNEN may qualify for fulfilment of LEED 2009 credit EQ c4.2 (paints and coatings).

18 June 2012

Inge Bondgaard
Chemical engineer

Eurofins Product Testing A/S
Smedeskovvej 38
DK 8464 Galten / Denmark

Tel +45 70 22 42 76
Fax +45 70 22 42 75

www.product-testing.eurofins.com